



Water Stewardship

Office of Drinking Water

1007 Century Street, Winnipeg MB R3H 0W4

**PERMIT TO CONSTRUCT OR ALTER
A SEMI-PUBLIC WATER SYSTEM**

PERMIT NUMBER: SPWS-11-P04

**THE DRINKING WATER SAFETY ACT
CCSM CAP C. 36**

WATER SYSTEM CODE: 3133.00

EFFECTIVE DATE: 15 SEPTEMBER 2011

EXPIRY DATE: 15 SEPTEMBER 2012

IN ACCORDANCE WITH *THE DRINKING WATER SAFETY ACT*, THIS PERMIT IS ISSUED PURSUANT TO SUBSECTION 7(1) TO:

NATURIST LEGACY INC.: "THE PERMITTEE"

FOR THE CONSTRUCTION OF A SEMI-PUBLIC WATER SYSTEM FOR THE NATURIST LEGACY CAMPGROUND LOCATED WITHIN 9-15-7 EPM IN THE RURAL MUNICIPALITY OF BROKENHEAD INCLUDING ESTABLISHMENT OF A WELL WATER SUPPLY, INSTALLATION OF A WATER FILL STATION AND 80m OF WATER DISTRIBUTION MAINS AS SPECIFIED IN THE PERMIT APPLICATION SUBJECT TO THE ATTACHED TERMS AND CONDITIONS.

THIS PERMIT DOES NOT AFFECT THE PERMITTEE'S OBLIGATIONS WITH RESPECT TO COMPLIANCE WITH ALL APPLICABLE MUNICIPAL, PROVINCIAL AND FEDERAL LEGISLATION.

DATE: 16 September 2011

Kimberley A. Philip, P.Eng.
Director

TERMS AND CONDITIONS

1. GENERAL

- 1.1. The Permittee shall ensure installation of the approved works in accordance with the documents submitted, supplier requirements and the requirements of this permit.
- 1.2. This Permit may be amended by the Director where in the opinion of the Director, an amendment is necessary to provide for the safety of water obtained from the water system and for the purposes of effective environmental management.
- 1.3. The Permittee may request an amendment to this permit by submitting an amendment application to the Office of Drinking Water.
- 1.4. This Permit may be suspended or cancelled by the Director for any of the reasons identified in Section 6 of Manitoba Regulation 40/2007 Drinking Water Safety Regulation or due to a failure to comply with any term or condition of this permit.
- 1.5. The Permittee shall provide written notice to the Office of Drinking Water of any change in title/ownership of the water system within 30 days of the transfer of title/ownership.

2. CONSTRUCTION – GENERAL

- 2.1. The Permittee shall provide copies of this permit and any subsequent amendments to all suppliers, staff or inspectors who may be involved with the installation and operation of the approved water system works.
- 2.2. The Permittee shall ensure the approved water system works are installed by the expiry date indicated on the Permit. If installation is not completed by the expiry date of the Permit, the Permit is deemed to have expired and a new permit application is required.

3. CONSTRUCTION – MATERIALS

- 3.1. The Permittee shall ensure that all components of the approved potable water system works and associated appurtenances including water piping are CSA certified, ANSI/NSF certified or meet other applicable standards for use in potable water systems.
- 3.2. The Permittee shall ensure that all materials used in the construction of the approved potable water system works are kept as clean as possible during installation to prevent contamination.

4. COMMISSIONING OF THE NEW WORKS

- 4.1. The Permittee shall ensure that all water lines and associated appurtenances are disinfected with a chlorine solution prior to the commencement of operations in accordance with the Office of Drinking Water *Seasonal Water System Start-up/Shut-down Protocol* or The Manitoba Water Services Board Standard Construction Specifications January 2000 Section 02706 Clause 3.20.
- 4.2. Following disinfection and flushing of the new water lines, the Permittee shall submit two sets of samples from the fill station and washroom building taken a minimum of 48 hours apart to an accredited laboratory for bacterial analysis.
- 4.3. The Permittee shall contact the Drinking Water Officer once confirmatory bacterial analysis results are received, prior to placing the new water system into operation.

5. DOCUMENTATION

- 5.1. The Permittee shall submit an application for a Semi-Public Water System Operating Licence to the Drinking Water Officer at least 30 days prior to the expected date the semi-public water system works will be placed into operation.